



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

C-1

Lab# 043

<u>Customer</u>	<u>Sample Collection</u>					
Facility Name:	Carnegie Mellon	Date:	11/25/25			
Address:	5000 Forbes Ave. Pittsburgh, PA 15213	Time:	9:08 AM			
Matrix:	<u>Sample Final Analysis</u>					
Source Type:	Recreational Water	Date:	11/28/25			
	Lap pool Shallow	Time:	10:30 AM			
		Analyst:	AS			
<u>Accredited Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Incubation Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
Escherichia Coli:	Absent	Absent	11/26/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/26/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/25/25	4:45 PM	AS	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.4 SU	7.2 - 7.8 SU	11/25/25	9:08 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/25/25	9:08 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/25/25	9:08 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor