

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2434

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Residence at the Docks

Address: 501 Riverfront Dr.

Pittsburgh, PA 15238

Matrix: Recreational Water

viatrix. Necreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25

Time: 10:55 AM Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	10:55 AM	ВН	DPD	
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/12/25	10:55 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:55 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2434

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Residence at the Docks

Address: 501 Riverfront Dr.

Pittsburgh, PA 15238

Matrix: Recreational Water

viatrix. Necreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25

Time: 10:55 AM Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	SL	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	10:55 AM	ВН	DPD	
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/12/25	10:55 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:55 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor