



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2507**

**Customer**

**Facility Name:** Stanford Court  
**Address:** 1200 Stanford Ct.  
Coraopolis, PA 15108

**Sample Collection**

**Date:** 8/6/25  
**Time:** 8:00 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/8/25  
**Time:** 2:00 PM  
**Analyst:** AS

**Source Type:** Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25 3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/6/25 8:00 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/6/25 8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25 8:00 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2507**

**Customer**

**Facility Name:** Stanford Court  
**Address:** 1200 Stanford Ct.  
Coraopolis, PA 15108

**Sample Collection**

**Date:** 8/6/25  
**Time:** 8:00 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/8/25  
**Time:** 2:00 PM  
**Analyst:** AS

**Source Type:** Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25 3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/6/25 8:00 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/6/25 8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25 8:00 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor