

Dreams Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665

Laboratory Analysis Report Lab

Lab# 018

PPS

Customer

Address:

Facility Name: Baxter Building

925 Brushton Ave

Pittsburgh, PA 15208

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 8/26/25 Time: 9:45 AM

Method: Grab

Sample Final Analysis

Date: 8/29/25 Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Α	8/27/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	Α	8/27/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	Α	8/26/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Rating	D	ate/Time	Analyst	Method
pH:	7.6 SU	Α	8/26/25	9:45 AM	EJ	DPD
Chlorine:	3.0 mg/l	Α	8/26/25	9:45 AM	EJ	DPD
Turbidity:	1 NTU	Α	8/26/25	9:45 AM	EJ	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor