



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2375**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *OakHill - Wadsworth*  
  
*Address:*            *480 Oak Hill Dr*  
                              *Pittsburgh, Pa 15213*

*Date:*                    *6/9/25*  
*Time:*                *12:05 PM*  
*Method:*             *Grab*

**Sample Final Analysis**

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Pool*

*Date:*                    *6/12/25*  
*Time:*                *9:30 AM*  
*Analyst:*              *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	3:29 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:05 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:05 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:05 PM	LM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2375**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *OakHill - Wadsworth*  
  
*Address:*            *480 Oak Hill Dr*  
                              *Pittsburgh, Pa 15213*

*Date:*                    *6/9/25*  
*Time:*                 *12:05 PM*  
*Method:*              *Grab*

**Sample Final Analysis**

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Pool*

*Date:*                    *6/12/25*  
*Time:*                 *9:30 AM*  
*Analyst:*               *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	3:29 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:05 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:05 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:05 PM	LM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor