



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2594**

**Customer**

**Facility Name:** Woodbridge Condo  
**Address:** 100 Club House Ln.  
Pittsburgh, PA 15237

**Sample Collection**

**Date:** 6/2/25  
**Time:** 9:17 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 6/5/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25 10:30 AM	EB	SM 9222G
Total coliforms:	2/100mls	2/100mls	6/3/25 10:30 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	6/2/25 5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/2/25 9:17 AM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/2/25 9:17 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25 9:17 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2594**

**Customer**

**Facility Name:** Woodbridge Condo  
**Address:** 100 Club House Ln.  
Pittsburgh, PA 15237

**Sample Collection**

**Date:** 6/2/25  
**Time:** 9:17 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 6/5/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	10:30 AM	EB	SM 9222G
Total coliforms:	2/100mls	2/100mls	6/3/25	10:30 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/2/25	9:17 AM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/2/25	9:17 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	9:17 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor