



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2178**

**Customer**

Facility Name: Estates of Forest Grove

**Sample Collection**

Date: 6/4/25

Time: 8:00 AM

Method: Grab

Address: 1500 Meerschaum Ln.  
Kennedy, PA 15108

**Sample Final Analysis**

Date: 6/6/25

Time: 4:00 PM

Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	8:00 AM	VH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/4/25	8:00 AM	VH DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	8:00 AM	VH Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2178**

<b><u>Customer</u></b>		<b><u>Sample Collection</u></b>				
Facility Name:	Estates of Forest Grove	Date:	6/4/25			
Address:	1500 Meerschaum Ln. Kennedy, PA 15108	Time:	8:00 AM			
Matrix:		<b><u>Sample Final Analysis</u></b>				
Source Type:	Recreational Water	Date:	6/6/25			
	Pool	Time:	4:00 PM			
		Analyst:	AS			
<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	8:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/4/25	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	8:00 AM	VH	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor