

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2171

Customer

Facility Name: Edgewood Club

Address: 1 Pennwood Ave

Pittsburgh, PA 15218

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 7/28/25 Time: 1:05 PM

Method: Grab

Sample Final Analysis

Date: 7/31/25 Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	1:05 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:05 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:05 PM	EH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2171

Customer

Facility Name: Edgewood Club

Address: 1 Pennwood Ave

Pittsburgh, PA 15218

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 7/28/25 Time: 1:05 PM

Method: Grab

Sample Final Analysis

Date: 7/31/25 Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	1:05 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:05 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:05 PM	EH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor