



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 373**

**Customer**

Facility Name: Pine Richland H.S.

Address: 700 Warrendale Rd.  
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 7/2/25

Time: 12:25 PM

Method: Grab

**Sample Final Analysis**

Date: 7/4/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/2/25	12:25 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/2/25	12:25 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	12:25 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

  
Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 373**

**Customer**

Facility Name: Pine Richland H.S.

Address: 700 Warrendale Rd.  
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 7/2/25

Time: 12:25 PM

Method: Grab

**Sample Final Analysis**

Date: 7/4/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/2/25	12:25 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/2/25	12:25 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	12:25 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

  
Andre Smith, Lead Supervisor