

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 SERVICE

Lab# 313

Customer				Sample Colle	ection	
Facility Name:	UPMC Sports Rehab - Cranberry			Date:	8/19/25	
·	•		•	Time:	11:20 AM	
Address:		erry Springs Drive		Method:	Grab	
	Cranberry To	wnship, PA 16066				
Matrice	Recreational Water			Sample Final Analysis Date: 8/22/25		
Matrix:				Date: Time:	8/22/25 9:00 AM	
Source Type:	Spa			Analyst:	9.00 AN	
Godioo Typo.	ορα			7 inaryot.	710	
Accredited Analysis	Results	Reporting limit	Incubatio	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	11:00 AM	EB	SM 9222G
		_,,,				
Total coliforms:	0/100mls	2/100mls	8/20/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	5:20 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
· · · · · · · · · · · · · · · · · · ·					-	
Fecal Streptococcus	0/100mls	2/100mls	8/20/25	11:15 AM	EB	SM 9230C
Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
nU.	7.4 SU	70 70 CH	8/19/25	11:20 AM	JR	DDD
pH:	1.4 30	7.2 - 7.8 SU	0/19/20	I I.ZU AIVI	JK	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/19/25	11:20 AM	JR	DPD
Officiality.	1.0 1119/1	1.0 0.0 1119/1	3/13/20	11.20 AW	OI (2, 5
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	11:20 AM	JR	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)