



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
E-2

Lab# 065

Customer

Facility Name: Wingate
Address: 106 Bair Blvd
New Stanton, PA 15672

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 10/27/25
Time: 9:38 AM
Method: Grab

Sample Final Analysis

Date: 10/30/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/27/25	9:38 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	10/27/25	9:38 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/25	9:38 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor