

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2709

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: District Sample Collection

Date: 7/22

me: District Date: 7/22/25 Time: 9:30 AM 1759 Waterfront Pl Method: Grab

Address: 1759 Waterfront Pl Pittsburgh, PA 15222

Matrix: Recreational Water Sample Final Analysis

Date: 7/25/25

Source Type: Pool Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	9:30 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/22/25	9:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:30 AM	LM	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2709

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: District Sample Collection

Date: 7/22

me: District Date: 7/22/25 Time: 9:30 AM 1759 Waterfront Pl Method: Grab

Address: 1759 Waterfront Pl Pittsburgh, PA 15222

Matrix: Recreational Water Sample Final Analysis

Date: 7/25/25

Source Type: Pool Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	9:30 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/22/25	9:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:30 AM	LM	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor