



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 191**

**Customer**

Facility Name: John H. Linton Large

Address: 250 Aster St.  
Penn Hills, PA 15235

Matrix: Recreational Water

Source Type: Large Pool

**Sample Collection**

Date: 7/14/25

Time: 10:20 AM

Method: Grab

**Sample Final Analysis**

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	10:20 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:20 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)



Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 191**

**Customer**

Facility Name: John H. Linton Large

Address: 250 Aster St.  
Penn Hills, PA 15235

Matrix: Recreational Water

Source Type: Large Pool

**Sample Collection**

Date: 7/14/25

Time: 10:20 AM

Method: Grab

**Sample Final Analysis**

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	10:20 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:20 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor