

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2169

<u>Customer</u> Facility Name:

Edgewood Club

Address:

1 Pennwood Ave.

Pittsburgh, PA 15218

Matrix:

Recreational Water

Source Type: Deep End

Sample Collection

Date:

6/23/25

Time:

1:28 PM

Method: Grab

Sample Final Analysis

Date:

6/26/25

Time: Analyst: 9:00 AM AS

Accredited Analysis	<u> </u>	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:		Absent	6/24/25	9:15 AM	EB	SM 9222G

Total coliforms:

Standard plate count:

0/100mls 0/ml

2/100mls

200/ml

6/24/25 6/23/25 9:15 AM 3:03 PM EB AH

SM 9215B

SM 9222B

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	1:28 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	1:28 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	1:28 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2169

<u>Customer</u> Facility Name:

Edgewood Club

Address:

1 Pennwood Ave.

Pittsburgh, PA 15218

Matrix:

Recreational Water

Source Type: Deep End

Sample Collection

Date:

6/23/25

Time:

1:28 PM

Method: Grab

Sample Final Analysis

Date:

6/26/25

Time: Analyst: 9:00 AM AS

Accredited Analysis	<u> </u>	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:		Absent	6/24/25	9:15 AM	EB	SM 9222G

Total coliforms:

Standard plate count:

0/100mls 0/ml

2/100mls

200/ml

6/24/25 6/23/25 9:15 AM 3:03 PM EB AH

SM 9215B

SM 9222B

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	1:28 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	1:28 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	1:28 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor