



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2776

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Brooks @ River's Edge

**Sample Collection**

Date: 6/3/25

Address: 54 1st Street  
Oalmont, PA 15139

Time: 2:45 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 6/6/25

Source Type: Pool

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	11:00 AM	AH
Total coliforms:	0/100mls	2/100mls	6/4/25	11:00 AM	AH
Standard plate count:	0/ml	200/ml	6/3/25	4:45 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/3/25	2:45 PM	BH
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/3/25	2:45 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	2:45 PM	BH

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2776

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Brooks @ River's Edge

**Sample Collection**

Date: 6/3/25

Address: 54 1st Street  
Oalmont, PA 15139

Time: 2:45 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 6/6/25

Source Type: Pool

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/4/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/3/25	2:45 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/3/25	2:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	2:45 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor