

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2020

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Apts of Cedar Ridge Date: 8/4/25
Time: 7:26 AM
Address: 250 Cedar Ridge Dr. Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 8/7/25
Time: 11:20 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	1:36 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	8/4/25	7:26 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/4/25	7:26 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	7:26 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2020

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Apts of Cedar Ridge Date: 8/4/25
Time: 7:26 AM
Address: 250 Cedar Ridge Dr. Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 8/7/25
Time: 11:20 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	1:36 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	8/4/25	7:26 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/4/25	7:26 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	7:26 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor