



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-13

Lab# 2086

Customer

Facility Name: Centennial Point
Address: 423 Patriot Dr.
Carnegie, PA 15106

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/5/25
Time: 7:33 AM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	7:33 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	7:33 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	7:33 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-13

Lab# 2086

Customer

Facility Name: Centennial Point
Address: 423 Patriot Dr.
Carnegie, PA 15106

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/5/25
Time: 7:33 AM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/5/25	7:33 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	7:33 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	7:33 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor