



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 183

Customer

Facility Name: Imperial House
Address: 5600 Munhall Rd.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/13/26
Time: 2:06 PM
Method: Grab

Sample Final Analysis

Date: 1/16/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/14/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/14/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/13/26	5:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	1/13/26	2:06 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/13/26	2:06 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/13/26	2:06 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor