



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**

Lab ID No. 02-04041

**S-10**

**Laboratory Analysis Report** Lab# 259

**Customer**

**Facility Name:** Providence Pointe  
**Address:** 301 Kane Boulevard  
Pittsburgh, PA 15243

**Sample Collection**

**Date:** 8/4/25  
**Time:** 12:48 PM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/7/25  
**Time:** 11:20 AM  
**Analyst:** AS

**Source Type:** Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	65/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/5/25	12:00 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	12:48 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:48 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:48 PM	CW	Visual

**Sample comments**



( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**

Lab ID No. 02-04041

**S-10**

**Laboratory Analysis Report** Lab# 259

**Customer**

Facility Name: Providence Pointe

Address: 301 Kane Boulevard  
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/4/25

Time: 12:48 PM

Method: Grab

**Sample Final Analysis**

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	1:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	1:15 PM	AH	SM 9222B
Standard plate count:	65/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/5/25	12:00 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	12:48 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:48 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:48 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor