



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2121**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/19/25*  
*Time: 1:10 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/22/25*  
*Time: 9:00 AM*  
*Analyst: AS*

*Facility Name:*

*Club at North Hills*

*Address:*

*700 Lincoln Club Drive*  
*Pittsburgh, PA 15237*

*Matrix:*

*Recreational Water*

*Source Type:*

*Pool*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/20/25              | 11:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/20/25              | 11:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/19/25              | 5:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/19/25   | 1:10 PM | MM      | DPD    |
| Chlorine:      | 4.0 mg/l | 1.0 - 5.0 mg/l  | 8/19/25   | 1:10 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/19/25   | 1:10 PM | MM      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor