

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

W-11

Lab ID No. 02-04041

VV-11

Lab# 414

Customer	Sample Collection

Facility Name: Townplace Suites Airport Date: 5/27/25
Time: 10:15 AM

Address: 1006 Sutherland Dr. Method: Grab

Pittsburgh, PA 15205

Matrix: Recreational Water Sample Final Analysis

Date: 5/30/25

Source Type: Spa Time: 9:00 AM Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	5/27/25	2:55 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	10:15 AM	VH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:15 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:15 AM	VH	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

W-11

Lab ID No. 02-04041

VV-11

Lab# 414

Customer	Sample Collection

Facility Name: Townplace Suites Airport Date: 5/27/25
Time: 10:15 AM

Address: 1006 Sutherland Dr. Method: Grab

Pittsburgh, PA 15205

Matrix: Recreational Water Sample Final Analysis

Date: 5/30/25

Source Type: Spa Time: 9:00 AM Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	5/27/25	2:55 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	5/27/25	10:15 AM	VH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:15 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:15 AM	VH	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)