



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 372**

**Customer**

*Facility Name:* Pine Richland H.S.

*Address:* 700 Warrendale Rd.  
Gibsonia, PA 15044

*Matrix:* Recreational Water

*Source Type:* Deep End

**Sample Collection**

*Date:* 10/20/25

*Time:* 10:20 AM

*Method:* Grab

**Sample Final Analysis**

*Date:* 10/23/25

*Time:* 10:30 AM

*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/21/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/20/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/20/25 10:20 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/20/25 10:20 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/25 10:20 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor