



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2434

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Residence at the Docks

Sample Collection

Date: 8/26/25

Time: 10:30 AM

Method: Grab

Address: 501 Riverfront Dr.
Pittsburgh, PA 15238

Sample Final Analysis

Date: 8/29/25

Time: 10:30 AM

Matrix: Recreational Water

Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS
Standard plate count:	0/ml	200/ml	8/26/25	5:30 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/26/25	10:30 AM	BH
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/26/25	10:30 AM	BH
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	10:30 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor