



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2669

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>
Facility Name:	Lincoln House	Date: 8/5/25
Address:	245 Lincoln Ave. Pittsburgh, PA 15202	Time: 10:16 AM Method: Grab
Matrix:	Recreational Water	<b><u>Sample Final Analysis</u></b>
Source Type:	Pool	Date: 8/8/25 Time: 8:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	3:30 PM	AH
Total coliforms:	0/100mls	2/100mls	8/6/25	3:30 PM	AH
Standard plate count:	0/ml	200/ml	8/5/25	6:45 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/5/25	10:16 AM	MM
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:16 AM	MM
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:16 AM	Visual

**Sample comments**

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2669

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>
Facility Name:	Lincoln House	Date: 8/5/25
Address:	245 Lincoln Ave. Pittsburgh, PA 15202	Time: 10:16 AM Method: Grab
Matrix:	Recreational Water	<b><u>Sample Final Analysis</u></b>
Source Type:	Pool	Date: 8/8/25 Time: 8:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	3:30 PM	AH
Total coliforms:	0/100mls	2/100mls	8/6/25	3:30 PM	AH
Standard plate count:	0/ml	200/ml	8/5/25	6:45 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/5/25	10:16 AM	MM
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:16 AM	MM
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:16 AM	Visual

**Sample comments**

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor