



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 202**

**Customer**

Facility Name: L.A. Fitness Greensburg

Address: 3000 Lincoln Place  
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/29/25

Time: 3:50 PM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 3:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25 6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25 6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/29/25 3:50 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/29/25 3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25 3:50 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 202**

**Customer**

Facility Name: *L.A. Fitness Greensburg*

Address: *3000 Lincoln Place  
Greensburg, PA 15601*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *5/29/25*

Time: *3:50 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *5/31/25*

Time: *3:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/29/25	3:50 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/29/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	3:50 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor