



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2628

Customer

Facility Name: Buena Vista Fire Company

Address: 3333 Fire Station St.
Buena Vista, PA 15018

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/10/25

Time: 12:30 PM

Method: Grab

Sample Final Analysis

Date: 6/13/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/11/25 | 10:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/11/25 | 10:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/10/25 | 3:12 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 6/10/25 | 12:30 PM | JC | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/10/25 | 12:30 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/10/25 | 12:30 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2628

Customer

Facility Name: Buena Vista Fire Company
Address: 3333 Fire Station St.
Buena Vista, PA 15018

Sample Collection

Date: 6/10/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 6/13/25
Time: 9:30 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/11/25 | 10:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/11/25 | 10:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/10/25 | 3:12 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 6/10/25 | 12:30 PM | JC | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/10/25 | 12:30 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/10/25 | 12:30 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor