



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 170

Customer

Facility Name: *Homewood Suites By Hilton*

Address: *1410 Smallman St*
Pittsburgh, PA 15222

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/23/25*

Time: *9:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *12/26/25*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/24/25	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/24/25	10:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/23/25	4:20 PM	JC	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/23/25	9:45 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/23/25	9:45 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/23/25	9:45 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor