



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 048

Customer

Facility Name: Chartiers Valley High School

Address: 50 Thoms Run Rd.
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 1/14/26

Time: 3:50 PM

Method: Grab

Sample Final Analysis

Date: 1/16/26

Time: 5:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/14/26	5:18 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/14/26	5:18 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/14/26	5:18 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	1/14/26	3:50 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	1/14/26	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/14/26	3:50 PM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)