



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 181

Customer

Facility Name: Hyatt Regency Airport

Address: 1111 Airport Boulevard
Pittsburgh, PA 15231

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/26/25

Time: 1:48 PM

Method: Grab

Sample Final Analysis

Date: 8/29/25

Time: 10:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/27/25 | 11:00 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/27/25 | 11:00 AM | AS | SM 9222B |
| Standard plate count: | 300/ml | 200/ml | 8/26/25 | 4:55 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/26/25 | 1:48 PM | AMH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/26/25 | 1:48 PM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/26/25 | 1:48 PM | AMH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor