



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 079**

**Customer**

**Facility Name:** Courtyard by Marriott  
**Address:** 700 Powerline Dr.  
Greensburg, PA 15601

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 9/22/25  
**Time:** 12:20 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 9/25/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Escherichia Coli:	Absent	Absent	9/23/25	9:30 AM	JC	SM 9222G
-------------------	--------	--------	---------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	9/23/25	9:30 AM	JC	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	9/22/25	4:00 PM	SL	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/23/25	10:30 AM	JC	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	9/22/25	12:20 PM	JC	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/22/25	12:20 PM	JC	DPD
-----------	-----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	9/22/25	12:20 PM	JC	Visual
------------	-------	-----------	---------	----------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor