



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 231

Customer

Facility Name: Moon Area High School

Address: 8353 University Blvd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 11/10/25

Time: 9:43 AM

Method: Grab

Sample Final Analysis

Date: 11/13/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 11/11/25 9:50 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/11/25 9:50 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 11/10/25 5:10 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 11/10/25 9:43 AM | AMH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 11/10/25 9:43 AM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/10/25 9:43 AM | AMH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)