



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 133**

**Customer**

Facility Name: Hampton Inn - Uniontown

Address: 698 West Main Street  
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 1/5/26

Time: 1:45 PM

Method: Grab

**Sample Final Analysis**

Date: 1/8/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Escherichia Coli:	Absent	Absent	1/6/26	10:00 AM	JC	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	1/6/26	10:00 AM	JC	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	1/5/26	5:00 PM	SL	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
---------------------	---------	-----------------	------------	-----------	---------	--------

Non-accredited

Fecal Streptococcus	0/100mls	2/100mls	1/6/26	10:10 AM	SL	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
----------------	---------	-----------------	--	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	1/5/26	1:45 PM	SH	DPD
-----	--------	--------------	--------	---------	----	-----

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	1/5/26	1:45 PM	SH	DPD
-----------	----------	----------------	--------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	1/5/26	1:45 PM	SH	Visual
------------	-------	-----------	--------	---------	----	--------

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)