



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2021**

**Customer**

Facility Name: Ascent 430  
Address: 430 Ascent Dr.  
Marshall Twp., PA 15086

**Sample Collection**

Date: 6/23/25  
Time: 9:49 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 6/26/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:14 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	9:49 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	9:49 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	9:49 AM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2021**

**Customer**

**Facility Name:** Ascent 430  
**Address:** 430 Ascent Dr.  
Marshall Twp., PA 15086

**Sample Collection**

**Date:** 6/23/25  
**Time:** 9:49 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 6/26/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:14 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	9:49 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	9:49 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	9:49 AM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*