



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2153**

**Customer**

Facility Name: *Dominion Homeowners*

Address: *1484 Zenith Court*  
*Pittsburgh, PA 15241*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/24/25*

Time: *12:09 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/27/25*

Time: *9:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	12:09 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/24/25	12:09 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:09 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 2153**

**Customer**

**Facility Name:** *Dominion Homeowners*

**Address:** *1484 Zenith Court  
Pittsburgh, PA 15241*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/24/25*

**Time:** *12:09 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/27/25*

**Time:** *9:20 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	12:09 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/24/25	12:09 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:09 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor