



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2739

Customer

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spray Pad

Sample Collection

Date: 5/28/25

Time: 9:15 AM

Method: Grab

Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 9:30 AM | SL | SM 9222G |
| Total coliforms: | 1/100mls | 2/100mls | 5/29/25 | 9:30 AM | SL | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 5/28/25 | 3:25 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/28/25 | 9:15 AM | VH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 9:15 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 9:15 AM | VH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2739

Customer

Facility Name: Chartiers Valley C.C.

Address: 601 Baldwin Road
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spray Pad

Sample Collection

Date: 5/28/25

Time: 9:15 AM

Method: Grab

Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 9:30 AM | SL | SM 9222G |
| Total coliforms: | 1/100mls | 2/100mls | 5/29/25 | 9:30 AM | SL | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 5/28/25 | 3:25 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/28/25 | 9:15 AM | VH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 9:15 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 9:15 AM | VH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor