



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2363

Customer

Facility Name: Mount Vernon Apts
Address: 2300 Surrey Lane
McKeesport, PA 15135

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/15/25
Time: 12:16 PM
Method: Grab

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	10:10 AM	AH
Total coliforms:	0/100mls	2/100mls	7/16/25	10:10 AM	AH
Standard plate count:	0/ml	200/ml	7/15/25	4:00 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/15/25	12:16 PM	JC
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/15/25	12:16 PM	JC
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	12:16 PM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2363

Customer

Facility Name: Mount Vernon Apts
Address: 2300 Surrey Lane
McKeesport, PA 15135

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/15/25
Time: 12:16 PM
Method: Grab

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	10:10 AM	AH
Total coliforms:	0/100mls	2/100mls	7/16/25	10:10 AM	AH
Standard plate count:	0/ml	200/ml	7/15/25	4:00 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/15/25	12:16 PM	JC
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/15/25	12:16 PM	JC
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	12:16 PM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor