



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 068

Customer

Facility Name: Cornell High School
Address: 1099 Maple St
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 10/20/25
Time: 10:00 AM
Method: Grab

Sample Final Analysis

Date: 10/23/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/21/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/20/25	5:04 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/20/25	10:00 AM	AMH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	10/20/25	10:00 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/25	10:00 AM	AMH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor