



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2121

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	Matrix:	Source Type:	<b><u>Sample Collection</u></b>		
				Date:	Time:	Method:
Club at North Hills	700 Lincoln Club Drive Pittsburgh, PA 15237	Recreational Water	Pool	8/4/25	12:56 PM	Grab
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	5:30 PM	AS	SM 9215B

<b><u>Field Analysis</u></b>	<b><u>Results</u></b>	<b><u>Reporting limit</u></b>	<b><u>Date/Time</u></b>	<b><u>Analyst</u></b>	<b><u>Method</u></b>	
pH:	7.8 SU	7.2 - 7.8 SU	8/4/25	12:56 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:56 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:56 PM	MM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2121

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	Matrix:	Source Type:	<b><u>Sample Collection</u></b>		
				Date:	Time:	Method:
Club at North Hills	700 Lincoln Club Drive Pittsburgh, PA 15237	Recreational Water	Pool	8/4/25	12:56 PM	Grab
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	5:30 PM	AS	SM 9215B

<b><u>Field Analysis</u></b>	<b><u>Results</u></b>	<b><u>Reporting limit</u></b>	<b><u>Date/Time</u></b>	<b><u>Analyst</u></b>	<b><u>Method</u></b>	
pH:	7.8 SU	7.2 - 7.8 SU	8/4/25	12:56 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:56 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:56 PM	MM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor