



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-10**

**Lab# 2073**

**Customer**

Facility Name: *Camp Guyasuta*  
  
Address: *300 23rd Street*  
*Sharpsburg, PA 15215*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *7/22/25*  
Time: *10:10 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/25/25*  
Time: *10:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	SL	SM 9222B
Standard plate count:	56/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	10:10 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:10 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:10 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-10**

**Lab# 2073**

**Customer**

Facility Name: *Camp Guyasuta*  
  
Address: *300 23rd Street*  
*Sharpsburg, PA 15215*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *7/22/25*  
Time: *10:10 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/25/25*  
Time: *10:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	SL	SM 9222B
Standard plate count:	56/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	10:10 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:10 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:10 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor