



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2498

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Southpointe Towers

Sample Collection

Date: 8/18/25

Address: 100 Celasi Dr.
West Mifflin, PA 15122

Time: 7:40 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/21/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/19/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	10:00 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	8/18/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/18/25	7:40 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/18/25	7:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	7:40 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor