



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2431**

**Customer**

Facility Name: Redwood Estates  
Address: 100 Redwood Dr.  
Oakdale, PA 15071

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/5/25  
Time: 9:55 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/8/25  
Time: 8:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	9:55 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	9:55 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	9:55 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2431**

**Customer**

Facility Name: Redwood Estates  
Address: 100 Redwood Dr.  
Oakdale, PA 15071

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 8/5/25  
Time: 9:55 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/8/25  
Time: 8:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	9:55 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	9:55 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	9:55 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor