



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 019

Customer

Facility Name: Baxter Building
Address: 925 Brushton Ave
Pittsburgh, PA 15208

Matrix: Recreational Water
Source Type: Pool Shallow

Sample Collection

Date: 6/25/25
Time: 12:45 PM
Method: Grab

Sample Final Analysis

Date: 6/27/25
Time: 4:30 PM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/25/25	5:40 PM	EB	SM 9222G
Total coliforms:	0/100mls	A	6/25/25	5:40 PM	EB	SM 9222B
Standard plate count:	0/ml	A	6/25/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	6/25/25	12:45 PM	BH	DPD
Chlorine:	2.0 mg/l	B	6/25/25	12:45 PM	BH	DPD
Turbidity:	1 NTU	A	6/25/25	12:45 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 019

Customer

Facility Name: *Baxter Building*
Address: *925 Brushton Ave*
Pittsburgh, PA 15208

Matrix: *Recreational Water*
Source Type: *Pool Shallow*

Sample Collection

Date: *6/25/25*
Time: *12:45 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/27/25*
Time: *4:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/25/25	5:40 PM	EB	SM 9222G
Total coliforms:	0/100mls	A	6/25/25	5:40 PM	EB	SM 9222B
Standard plate count:	0/ml	A	6/25/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	6/25/25	12:45 PM	BH	DPD
Chlorine:	2.0 mg/l	B	6/25/25	12:45 PM	BH	DPD
Turbidity:	1 NTU	A	6/25/25	12:45 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor