



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2036

Customer

Facility Name: *Bellvue Park*
Address: *Lambeth Dr.*
Cranberry, PA 16066

Sample Collection

Date: *6/23/25*
Time: *1:00 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *6/26/25*
Time: *9:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/24/25 | 9:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/24/25 | 9:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/23/25 | 3:14 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/23/25 | 1:00 PM | ZR | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/23/25 | 1:00 PM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/25 | 1:00 PM | ZR | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2036

Customer

Facility Name: Bellvue Park

Address: Lambeth Dr.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/23/25

Time: 1:00 PM

Method: Grab

Sample Final Analysis

Date: 6/26/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/24/25 | 9:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/24/25 | 9:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/23/25 | 3:14 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/23/25 | 1:00 PM | ZR | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/23/25 | 1:00 PM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/25 | 1:00 PM | ZR | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith