



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 356

Customer

Facility Name: YMCA - East Suburban

Address: 2200 Golden Mile Hwy.
Plum, PA 15239

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 1/27/26

Time: 2:57 PM

Method: Grab

Sample Final Analysis

Date: 1/30/26

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/28/26	11:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	1/27/26	2:57 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/27/26	2:57 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	2:57 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor