

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 297

Customer Sample Collection

Facility Name: Steel Valley High School Date: 6/16/25
Time: 11:30 AM

Address: 3113 Main Street Method: Grab

Munhall, PA 15120

Matrix: Recreational Water Sample Final Analysis

Date: 6/19/25

Time: 10:00 AM
Source Type: Shallow End Analyst: AS

**Accredited Analysis** Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 6/17/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/17/25 12:00 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/16/25 6:00 PM AS SM 9215B

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/16/25   | 11:30 AM | DW      | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 6/16/25   | 11:30 AM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/16/25   | 11:30 AM | DW      | Visual |

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 297

Customer Sample Collection

Facility Name: Steel Valley High School Date: 6/16/25
Time: 11:30 AM

Address: 3113 Main Street Method: Grab

Munhall, PA 15120

Matrix: Recreational Water Sample Final Analysis

Date: 6/19/25

Time: 10:00 AM
Source Type: Shallow End Analyst: AS

**Accredited Analysis** Results **Reporting limit Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 6/17/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/17/25 12:00 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/16/25 6:00 PM AS SM 9215B

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/16/25   | 11:30 AM | DW      | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 6/16/25   | 11:30 AM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/16/25   | 11:30 AM | DW      | Visual |

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor