



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2136

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Wynnwood @ Freedom Road*

Address: *501 Cranberry Pointe Lane*
Cranberry, PA 16066

Date: *6/23/25*
Time: *11:13 AM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool*

Date: *6/26/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	11:13 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:13 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	11:13 AM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2136

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Wynnwood @ Freedom Road*

Address: *501 Cranberry Pointe Lane*
Cranberry, PA 16066

Date: *6/23/25*
Time: *11:13 AM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool*

Date: *6/26/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	11:13 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:13 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	11:13 AM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor