

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-13

Lab ID No. 02-04041

Lab# 433

Customer

Atria Senior Living

Address:

Facility Name:

8870 Duncan Ave. Pittsburgh, PA 15237

Matrix:

Recreational Water

Pool Source Type:

Sample Collection

Date:

6/9/25 12:49 PM

Time: Method:

Grab

Sample Final Analysis Date:

6/12/25

Time:

9:30 AM

Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	ЕВ	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:49 PM	MM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:49 PM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:49 PM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-13

Lab ID No. 02-04041

Lab# 433

Customer

Atria Senior Living

Address:

Facility Name:

8870 Duncan Ave. Pittsburgh, PA 15237

Matrix:

Recreational Water

Pool Source Type:

Sample Collection

Date:

6/9/25 12:49 PM

Time: Method:

Grab

Sample Final Analysis Date:

6/12/25

Time:

9:30 AM

Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	ЕВ	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:49 PM	MM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:49 PM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:49 PM	MM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor