



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 179

## Laboratory Analysis Report

### Customer

Facility Name: Hyatt Place  
Address: 6011 Campbells Run Rd  
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 1/20/26  
Time: 11:00 AM  
Method: Grab

### Sample Final Analysis

Date: 1/23/26  
Time: 10:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/21/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/21/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/20/26	4:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	1/20/26	11:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/20/26	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/20/26	11:00 AM	VH	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor