# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

## CP

*Lab#* **2443**

| *Customer* | | *Sample Collection* | |
|---|---|---|---|
| *Facility Name:* | Riverview | *Date:* | 6/30/25 |
| | | *Time:* | 1:45 PM |
| *Address:* | 400 Riverview Ave. | *Method:* | Grab |
| | Pittsburgh, PA 15214 | | |
| | | *Sample Final Analysis* | |
| *Matrix:* | Recreational Water | *Date:* | 7/3/25 |
| | | *Time:* | 9:30 AM |
| *Source Type:* | Deep End | *Analyst:* | AS |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 4:10 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 6.8  SU | 7.2 - 7.8 SU | 6/30/25 | 1:45 PM | WB | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 1:45 PM | WB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 1:45 PM | WB | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor

## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

## CP

*Lab#* **2443**

---

| | | | |
|---|---|---|---|
| ***Customer*** | | ***Sample Collection*** | |
| *Facility Name:* | *Riverview* | *Date:* | *6/30/25* |
| | | *Time:* | *1:45 PM* |
| *Address:* | *400 Riverview Ave.* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15214* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *7/3/25* |
| | | *Time:* | *9:30 AM* |
| *Source Type:* | *Deep End* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 4:10 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 6.8 SU | 7.2 - 7.8 SU | 6/30/25 | 1:45 PM | WB | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 1:45 PM | WB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 1:45 PM | WB | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor