



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2063**

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Sample Collection**

*Facility Name:*      *Brook Park Swim Club*  
*Address:*      *8190 Rochester Rd*  
Pittsburgh, PA 15237

*Date:*      8/20/25  
*Time:*      11:39 AM  
*Method:*      Grab

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
*Source Type:*      *Shallow End*

*Date:*      8/22/25  
*Time:*      3:30 PM  
*Analyst:*      AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	5:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	5:45 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/20/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/20/25	11:39 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/20/25	11:39 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/20/25	11:39 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor